

**WARRANTY  
REGISTRATION:**  
register online today for a  
chance to win a FREE Tripp Lite  
product—[www.tripplite.com/warranty](http://www.tripplite.com/warranty)



# Owner's Manual

## Medical-Grade, Mobile Power Retrofit Kit

*Model #: HCRK-2*

**Kit Includes: Power Supply Module, Battery Module, Remote User Interface (RUI),  
PowerAlert Data-Saving Software, Mounting Hardware and Cables.**

Fully tested, certified and compliant to:

• UL 60601-1 • CAN/CSA-C22.2 No. 601.1-M90 • UL 1778

by



|   |           |
|---|-----------|
| <b>Important Safety Instructions</b>        | <b>2</b>  |
| <b>Mounting</b>                             | <b>3</b>  |
| <b>Connection / Start-Up</b>                | <b>5</b>  |
| <b>Operation</b>                            | <b>7</b>  |
| <b>Features</b>                             | <b>8</b>  |
| <b>Troubleshooting</b>                      | <b>10</b> |
| <b>Storage &amp; Service</b>                | <b>11</b> |
| <b>Safety &amp; Regulatory Statements</b>   | <b>11</b> |
| <b>Warranty &amp; Warranty Registration</b> | <b>12</b> |



1111 W. 35th Street, Chicago, IL 60609 USA  
(773) 869-1234 • [www.tripplite.com](http://www.tripplite.com)

Copyright © 2006 Tripp Lite. All rights reserved.

## Important Safety Instructions



Tripp Lite's Medical-Grade, Mobile Power Retrofit Kit includes two modules: a Power Supply Module and a Battery Module. When the two modules are connected (and attached to a remote user interface), they provide AC power for a variety of equipment on mobile medical carts. The following instructions refer to the kit as a single unit as well as its component parts.

### SAVE THESE INSTRUCTIONS

This manual contains instructions and warnings that should be followed during the installation, operation and storage of all Tripp Lite Medical-Grade, Mobile Power Retrofit Kits. Failure to heed these warnings will void your warranty.

### Power Supply Module & Battery Module Location Warnings

- Your Power Supply Module incorporates fusing only in the ungrounded phase conductor. UL 60601-1 certified Power Supply Modules must not be used in countries other than the United States and Canada and must be used only in health care facilities on grounded systems where conditions of maintenance and supervision ensure that only qualified persons will service the electrical distribution system.
- Install your Power Supply Module and Battery Module indoors, away from excess moisture or heat, dust or direct sunlight and conductive contaminants.
- Although the Power Supply Module is designed to support computer equipment, do not install it in direct contact with magnetic storage media, as this may result in data corruption.
- Your Power Supply Module and Battery Module are not suitable for use in the presence of a flammable anaesthetic mixture with air, oxygen or nitrous oxide.
- For best performance, keep the indoor temperature between 32° F and 104° F (0° C and 40° C).
- Leave adequate space around all sides of the Power Supply Module and Battery Module for proper ventilation.

### Power Supply Module Connection Warnings

- Do not operate the Power Supply Module without connecting it to a Battery Module and the Remote User Interface (RUI). The Power Supply Module will not operate (with or without utility power) until the Battery Module and RUI are connected.
- Do not allow objects to contact the Power Supply Module's two DC input terminals. Do not short or bridge these terminals together. Serious personal injury or property damage could result.
- Connect your Power Supply Module directly to a properly grounded AC power outlet. Do not plug the Power Supply Module into itself; this will damage the unit. The Power Supply Module features a hospital-grade plug. If the plug is connected to a wall outlet that is not hospital-grade, the unit may not be properly grounded.
- Do not modify the Power Supply Module's plug, and do not use an adapter that would eliminate the Power Supply Module's ground connection.
- Do not use extension cords to connect the Power Supply Module to an AC outlet.
- If the Power Supply Module receives power from a motor-powered AC generator, the generator must provide clean, filtered, computer-grade output.

### Equipment Connection Warnings

- Do not use Tripp Lite Power Supply Modules for life support devices in which a malfunction or failure of a Tripp Lite Power Supply Module could cause failure or significantly alter the performance of a life-support device.
- The Power Supply Module is designed to accept connection of equipment mounted on the same mobile cart. Connecting equipment which is not mounted on the same cart as the Power Supply Module could pose a safety hazard.
- Do not connect surge suppressors or extension cords to the output of your Power Supply Module. This may damage the Power Supply Module and will void the surge suppressor and Power Supply Module warranties.

## Important Safety Instructions continued



### Battery Module Warnings

- Do not allow objects to contact the Battery Module's two DC input terminals. Do not short or bridge these terminals together. Serious personal injury or property damage could result.
- It is normal for sparks to occur when connecting the Battery Module to the Power Supply Module.
- Due to the possibility of dangerous arcing, do not unplug the Battery Module from the Power Supply Module while the Power Supply Module is operating from battery power (whenever the cart is mobile and the Power Supply Module is not plugged into a live utility wall outlet).
- Your Battery Module does not require routine maintenance. Do not open your Battery Module for any reason. There are no user-serviceable parts inside. The batteries in the Battery Module will eventually wear out and be unable to provide adequate backup times. Internal battery replacement must be performed by factory authorized service personnel. Because batteries present a risk of electrical shock and burn from high short-circuit current, service personnel should observe proper precautions. Unplug the Battery Module before performing battery replacement. Do not short or bridge battery terminals with any object. Use tools with insulated handles. Remove metal objects such as watches and rings before working with batteries. Do not open batteries. Replace batteries only with sealed lead-acid batteries of the same number, type, voltage and amp-hour capacity. Contact Tripp Lite for details.
- Tripp Lite offers additional replacement Battery Modules (model #: BP12V82). Contact Tripp Lite for details.
- The Battery Module's internal batteries are recyclable. Refer to local codes for disposal requirements, or in the USA only call 1-800-SAV-LEAD or 1-800-8-BATTERY (1-800-8-228-8379) or visit [www.rbr.com](http://www.rbr.com) for recycling information. Do not dispose of the batteries in a fire.
- If connecting a replacement Battery Module to the Power Supply Module, the Battery Module must have the same voltage as the Power Supply Module. Use only Tripp Lite Battery Modules (model #: BP12V82) with the Power Supply Module.

### Labeling Symbols

AC Voltage: V~

DC Voltage: V==

Neutral Fusing: —

Electric Shock Hazard: ⚡

## Mounting



### WARNING!

Mount the Power Supply Module and Battery Module **BEFORE** connection.

**The mounting brackets are only designed to support a Tripp Lite Power Supply Module and a single Battery Module. Do not mount or place any other devices on the mounting brackets. The mounting brackets will not support the additional weight and may fail.**

**Failure to follow these warnings may lead to product damage and/or risk of personal bodily harm.**


The mounting bracket is only designed to fit specific mobile medical cart configurations (see diagrams). Tripp Lite offers additional mounting brackets for additional medical cart configurations. Contact Tripp Lite for details. The user must determine the fitness of the mounting hardware and procedures before mounting. If the hardware or procedures are not suitable for your application, contact Tripp Lite for assistance.

## Mounting continued

### 1 Power Supply Module & Battery Module Mounting


- 1A** Lay cart on its side and remove existing bracket from bottom of cart.\*

\* The existing bracket is not required for mounting or operation of Tripp Lite's Retrofit Kit. However, Tripp Lite's mounting tray includes holes that will accept the blocks from the existing bracket (if desired).




- 1B** Attach Power Supply Module to mounting tray with included hardware.\* Make sure that the Power Supply Module's outlets are facing opposite of where you will mount the Battery Module in step 1D. NOTE: the mounting tray features identical mounting holes on each side, allowing Power Supply Module and Battery Module to be mounted on either side of the cart.

\* Power Supply Hardware: four phillips-head screws (3/8 in. long, 10-32 size) and four star washers (#10).




- 1C** Attach mounting tray to bottom of cart with included hardware.\* To securely engage the cart's threaded holes, the included bolts must be screwed from the outside in (as shown). Access the cart's threaded holes by reaching inside the hollow crossbar that holds the cart's wheels.

\* Mounting Tray Hardware: ten hex bolts (3/8 in. long 1/4-20 size) and 10 lock washers.



- 1D** Stand cart upright. Attach Battery Module to mounting tray with included hardware.\*

\* Battery Module Hardware: four hex bolts (1-5/8 in. long 5/16-18 size), four hex nuts (5/16-18), four star washers (5/16) and four flat washers.



### 2 Remote User Interface (RUI) Mounting

Mount the Remote User Interface in a variety of positions on any flat surface using included double-sided tape.



#### CAUTION!

The double-sided tape quickly forms an extremely strong bond. This ensures the RUI will remain securely in position, meeting the requirements of demanding medical environments. Due to the tape's strong bond, position the RUI exactly where desired before pressing it into place.


## Connection / Start-Up

**NOTE:** Several adhesive cord-management devices are included. Use them, if desired, to keep cords and cables securely stowed after connection.

### 1 Connect the Remote User Interface (RUI) to the Power Supply Module


The Power Supply Module will not operate without the RUI connected. Connect the included grey cord\* from the RUI jack labeled “COMM1 GREY” to the Power Supply Module jack labeled “COMM1 GREY”. Connect the included black cord\* from the RUI jack labeled “COMM2 BLACK” to the Power Supply Module jack labeled “COMM2 BLACK”.

*\* If desired, you can substitute any standard Ethernet cable with RJ45 connectors in place of the included cords.*




### 2 Connect the Battery Module to the Power Supply Module

Your Power Supply Module has no internal batteries and must be connected to a Battery Module to operate. Make sure that the Battery Module’s cable is fully inserted into the Power Supply Module’s connector. Small sparks may result during battery connection; this is normal.



### 3 Plug In the Power Supply Module

Using the coiled AC power cord, plug the Power Supply Module into a live 120V AC utility wall outlet.



#### CAUTION!

The Power Supply Module features a hospital-grade plug. If the plug is connected to a wall outlet that is not hospital-grade, the unit may not be properly grounded.

### 4 Charge the Battery Module

When the Power Supply Module is plugged into a live AC wall outlet, it will automatically charge the Battery Module.



#### CAUTION!


The Power Supply Module must be plugged into a live AC utility wall outlet for 24 hours after initial installation to fully charge the Battery Module. If the Power Supply Module is plugged in and turned on, your connected equipment will receive utility-supplied AC power (if present); however, your connected equipment may not receive full battery backup when the Power Supply is mobile (disconnected from an AC outlet) unless the Battery Module is fully charged.

## Connection / Start-Up continued

### 5 Turn the Power Supply Module's Outlets ON

Press and hold the "Power" button\* for one second. The alarm will beep once briefly after one second has passed. Release the button. The "Power" LED\* will illuminate to indicate that the Power Supply Module's outlets are ON. The Battery Charge LED Meter\* will indicate the approximate charge level of the connected Battery Module.


\* Located on the Remote User Interface (RUI).



### 6 Plug Your AC Equipment into the Power Supply Module's Outlets

The Power Supply Module provides filtered, pure sine-wave 120V AC power for a variety of equipment—computers, monitors, diagnostic devices, scanners and more. You will overload the Power Supply Module if the total VA ratings for all the equipment you connect exceeds 200VA (the Power Supply Module's continuous output capacity).\*


\* To find your equipment's VA ratings, look on their nameplates. If the equipment is listed in amps, multiply the number of amps by 120 to determine VA. (Example: 1 amp x 120 = 120 VA).



### 7 OPTIONAL—Install PowerAlert Data-Saving Software

This connection is optional. The Power Supply Module and Battery Module will function properly without this connection. Using the included cable\*, connect the Power Supply Module's USB port to the USB port on any laptop or desktop computer mounted on the mobile cart. Insert the included PowerAlert CD and load the version of PowerAlert appropriate for the computer's operating system. Follow the setup and configuration screens for your specific application.

\* If desired, you can substitute standard USB cable in place of the included cable.



# Operation



## CAUTION!

The Power Supply will not provide output power to connected equipment in either of the following conditions: Battery Module or RUI disconnected;\* Battery Module fully discharged.\*\*

\* The user may need to turn on the Power Supply Module manually (using the RUI's "Power" button) after reconnection.

\*\* Battery Modules continuously left in a discharged state will suffer a permanent loss of capacity. Full recharge time is roughly equal to full discharge time.

## Mobile Operation (Unplugged / Battery Discharging)

Unplug the Power Supply Module from the AC wall outlet. Ensure that the cord is safely stowed aboard the cart to reduce the risk of damage.

Use connected equipment between charges, depending on battery conditions, environmental conditions and equipment load. Contact Tripp Lite for additional solutions to meet all your runtime needs. As the Battery Module's charge is depleted, the Battery Charge LED Meter will indicate the approximate charge level (see chart).

To turn the Power Supply Module's outlets (and any connected equipment) OFF and stop the battery from discharging, press the "Power" button for one second. The alarm will beep once briefly after one second has passed. Release the button. All LEDs will be OFF.

### Charge Level Indicators (Discharging)

**Battery Charge LED Meter Display**

| Approximate Battery Module Charge Level | LED 1        | LED 2  | LED 3 | LED 4 | Low Battery Alarm* |
|---|--------------|--------|-------|-------|--------------------|
| 90 - 100%                               | Green        | Green  | Green | Green | OFF                |
| 60% - 89%                               | Green        | Green  | Green | OFF   | OFF                |
| 31% - 59%                               | Yellow       | Yellow | OFF   | OFF   | ON                 |
| <= 30%                                  | Flashing Red | OFF    | OFF   | OFF   | ON                 |

\* The low battery alarm will beep once per second unless it is silenced by pressing the "Alarm Mute" button. Once the charge level falls below 30% (and shutdown is imminent) the alarm will resume again after one minute. The user should save open files and safely shut down connected equipment immediately. If the cart is unattended and PowerAlert Software is loaded on a computer connected to the Power Supply Module, PowerAlert will automatically save open files prior to automatic shutdown.

## Stationary Operation (Plugged In / Battery Charging)

Plug the Power Supply Module into a live AC wall outlet.\* The Power Supply Module will deliver AC power to connected equipment while simultaneously charging the Battery Module.

Use connected equipment indefinitely as long as the Power Supply is connected to a live AC outlet. If the utility power fails, due to a blackout or severe brownout, the Power Supply will automatically support connected equipment with AC power from the Battery Module (if adequately charged). When power resumes after a blackout, the Power Supply will automatically resume supplying AC power and recharging the Battery Module.

### Charge Level Indicators (Charging)

**Battery Charge LED Meter Display**

| Approximate Battery Module Charge Level | LED 1 | LED 2 | LED 3 | LED 4          |
|---|-------|-------|-------|----------------|
| 90 - 100%                               | Green | Green | Green | Green          |
| 60% - 89%                               | Green | Green | Green | Flashing Green |
| 31% - 59%                               | Green | Green | OFF   | Flashing Green |
| <= 30%                                  | Green | OFF   | OFF   | Flashing Green |

\* Tripp Lite recommends that the Power Supply be plugged into a wall outlet, charging the battery as often as possible. Charging the batteries for brief intervals DOES NOT adversely affect battery performance. However, leaving the batteries fully discharged for long periods of time DOES adversely affect battery performance.

## Features

### Remote User Interface (RUI):



**“Power” Button:** This button turns the Power Supply Module’s outlets (and any connected equipment) on and off.

**To turn the Power Supply Module’s outlets ON:** Press and hold the “Power” button for one second. The alarm will beep once briefly after one second has passed. Release the button. The “Power” LED will illuminate. The “Power” button will turn the outlets on regardless of whether the Power Supply Module is plugged in or not.


**To turn the Power Supply Module’s outlets OFF:** Press and hold the “Power” button for one second. The alarm will beep once briefly after one second has passed. Release the button. The “Power” LED will turn off.



**Alarm Mute Button:** This button silences the Power Supply Module’s low battery alarm. To silence the low battery alarm, briefly press and release the Alarm Mute button. The low battery alarm will beep once per second unless it is silenced. Once the charge level falls below 30% (and shutdown is imminent) the alarm will resume again after one minute. Once the charge level falls below 30%, the user should save open files and safely shut down connected equipment immediately. If the cart is unattended and PowerAlert Software is loaded on a computer connected to the Power Supply Module, PowerAlert will automatically save open files prior to automatic shutdown.



**“Power” LED:** This green LED indicates whether the Power Supply Module’s outlets are ON or OFF.



**Battery Charge LED Meter:** These LEDs will illuminate in several sequences to indicate the approximate charge level of the Battery Module. See “Operation” section for charts illustrating Battery Charge LED Meter Display depending on different charge levels while discharging and charging.



**Communications Jacks:** Connect the RUI to the Power Supply Module.

### Power Supply Module:



**AC Outlets:** Provide filtered, pure sine-wave 120V AC power for all equipment—computers, monitors, diagnostic devices, scanners and more.



**Coiled AC Input Cord with Hospital-Grade Plug:** Connects Power Supply Module to any 120V AC wall outlet.



## Features continued

### Power Supply Module continued:



**USB Port:** This port connects the Power Supply Module to any cart-mounted computer (laptop or desktop) with included cable. Use with PowerAlert Data-Saving Software (included on CD) to automatically save open patient data files and safely close applications if the Battery Module is depleted or if utility power is disconnected while the cart is unattended. Consult your PowerAlert manual (included on CD) for more information.



**Battery Connectors:** Use to connect the Power Supply Module to the Battery Module. Contact Tripp Lite for additional solutions to meet all your runtime needs.



**Cooling Fan:** Quiet, efficient fan regulates internal temperature and prolongs equipment service life. Fan runs intermittently depending on temperature and load.




**Communications Jacks:** Connects the Power Supply Module to the Remote User Interface (RUI).

**Isolation Transformer (Internal. Not Shown):** Provides UL 60601-1 compliance by managing current leakage of connected equipment.

**Automatic Transfer Switch—ATS (Internal. Not Shown):** Works automatically, whether plugged in or mobile. Allows Power Supply Module to simultaneously run connected equipment while recharging the Battery Module.

**Advanced, 3-Stage Battery Charger (Internal. Not Shown):** Recharges batteries safer and faster than conventional chargers. Faster charging ensures faster cart rotation between shifts.

### Battery Module:



**Battery Cable:** Use to connect the Battery Module to the Power Supply Module.



**DC Fuses:** Protect Battery Module from damaging overload. If fuse blows, replace with standard 25 amp automotive fuse. CAUTION: installing non-rated fuses could cause equipment damage and void your warranty.

## Troubleshooting

| Problem  | Possible Solutions   |
|--|--|
| No AC output power available at outlets.                           | <p><b>Turn Unit ON:</b> Turn the Power Supply Module ON using the “Power” Button. See “Connection / Start-Up” section for details.</p> <p><b>Check Connections:</b> Check to make sure the Power Supply Module and Battery Module are properly connected. Also, make sure the RUI is connected to the Power Supply Module. The Power Supply Module will not supply AC power without these connections. The user may need to turn on the Power Supply Module manually (using the RUI’s “Power” button) after reconnection. See “Connection / Start-Up” section for details.</p> <p><b>Recharge Battery Module:</b> If the Battery Module is fully discharged, the Power Supply Module will be unable to supply output power through its AC outlets. Allow the Battery Module to fully charge. See “Connection / Start-Up” section for details.</p> <p><b>Replace Blown Fuse:</b> Replace the Battery Module’s external fuses. Replace with 25-amp standard automotive blade-type fuses.</p> |
| Battery Module not recharging, even with AC utility power present. | <p><b>Check Connections:</b> Check to make sure the Power Supply Module and Battery Module are properly connected. Also, make sure the Power Supply Module’s power cord is plugged into a live AC wall outlet. See “Connection / Start-Up” section for details.</p> <p><b>Replace Blown Fuse:</b> Replace the Battery Module’s external fuses. Replace with 25-amp standard automotive blade-type fuses.</p> <p><b>Replace Battery Module:</b> The Battery Module will reliably supply backup power for several years with normal use. When the Battery Module reaches the end of its service life it will supply progressively diminishing capacity. Contact Tripp Lite for additional information.</p>   |
| Low battery alarm sounding.  | <p><b>Check Battery Charge Level LED Meter:</b> Silence the alarm, if desired, with the “Alarm Mute” button. Check LED meter to determine the percentage of charge remaining. (See “Operation” section for charts illustrating Battery Charge LED Meter Display depending on different charge levels while discharging and charging.) When the charge level falls below 30%, the Battery Module is nearly depleted and Power Supply Module shutdown is imminent. The user should save open files and safely shut down connected equipment immediately. If the cart is unattended and PowerAlert Software is loaded on a computer connected to the Power Supply Module, PowerAlert will automatically save open files prior to automatic shutdown.</p>  |

## Storage & Service

### Storage

For short term storage (when charging the Battery Module between shifts), see “Operation” section.



#### CAUTION!

**Even after the Power Supply Module is unplugged, its outlets may still deliver current, until it is disconnected from the Battery Module and completely turned OFF (deactivated).**

Before storing your Power Supply Module, make sure the Battery Module is fully charged. Then, turn the Power Supply Module completely OFF: unplug the Power Supply Module from the wall outlet, then press and hold the “Power” button for one second (an alarm will beep once briefly after the interval has passed). All LEDs and outlets should be OFF. Disconnect the Power Supply Module from the Battery Module. If you store your Power Supply Module and Battery Module for an extended period of time, recharge the Battery Module once every month. Follow the connection and recharge procedure in the “Connection / Start-Up” section. If you leave your Battery Module discharged for an extended period of time, it will suffer a permanent loss of capacity.

### Service

Before returning your Power Supply Module or Battery Module for service, follow these steps:

1. Review the installation and operation instructions in this manual to ensure that the service problem does not originate from a misreading of the instructions.
2. If the problem continues, do not contact or return the unit to the dealer. Instead, call Tripp Lite at (773) 869-1233. A service technician will ask for the Power Supply Module's and Battery Module's model numbers, serial numbers and purchase dates and will attempt to correct the problem over the phone.
3. If the problem requires service, the technician will issue you a Returned Material Authorization (RMA) number, which is required for service. If you require packaging, the technician can arrange to send you proper packaging. Securely pack the unit to avoid damage during shipping. Do not use Styrofoam beads for packaging. Any damages (direct, indirect, special, incidental or consequential) to the unit incurred during shipment to Tripp Lite or an authorized Tripp Lite service center is not covered under warranty. Power Supply Modules and Battery Supply Modules shipped to Tripp Lite or an authorized Tripp Lite service center must have transportation charges prepaid. Mark the RMA number on the outside of the package. If the unit is within the warranty period, enclose a copy of your sales receipt. Return the unit for service using an insured carrier to the address given to you by the Tripp Lite service technician.

## Safety & Regulatory Statements

It is the user's responsibility to verify and ensure that Tripp Lite's Medical-Grade, Mobile Power Retrofit Kit is appropriate for use within their specific application (meeting all safety and regulatory requirements for the application).

#### Regulatory Compliance Identification Numbers

For the purpose of regulatory compliance certifications and identification, your Tripp Lite product has been assigned a unique series number. The series number can be found on the product nameplate label, along with all required approval markings and information. When requesting compliance information for this product, always refer to the series number. The series number should not be confused with the marking name or model number of the product.

**UL CLASSIFICATION FOR MEDICAL EQUIPMENT:** Class I, Type B, Ordinary Equipment, Continuous Operation.

**UL60601-1 APPROVAL:** The Power Supply Module incorporates a Faraday-shielded isolation transformer that reduces the cumulative leakage current of all connected equipment to below 300 microamps.

**UL1778 APPROVAL:** The Power Supply Module described in this manual is UL1778 listed. It meets strict requirements for UPS protection. It provides battery backup during blackouts, switching between utility power and battery backup power in 2-4 milliseconds.

**FCC CLASS A RADIO/TV INTERFERENCE NOTICE:** Note: This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when operated in a commercial environment. This equipment generates, uses and can radiate radio frequency energy, and if not installed and used in accordance with the instruction manual, may cause interference to radio communications. Operation of this equipment is likely to cause harmful interference in which case the user will be required to correct the interference at their own expense. The user must use shielded cables and connectors with this product. Any changes or modifications to this product not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

## Warranty & Warranty Registration

### Limited Warranty

Tripp Lite warrants its Power Supply Module to be free from defects in materials and workmanship for a period of 2 years from the date of purchase by end user. Tripp Lite warrants its Battery Module to be free from defects in materials and workmanship for a period of 6 months from the date of purchase by end user. Tripp Lite's obligation under this warranty is limited to repairing or replacing (at its sole option) any such defective products. To obtain service under this warranty you must obtain a Returned Material Authorization (RMA) number from Tripp Lite or an authorized Tripp Lite service center. Products must be returned to Tripp Lite or an authorized Tripp Lite service center with transportation charges prepaid and must be accompanied by a brief description of the problem encountered and proof of date and place of purchase. This warranty does not apply to equipment which has been damaged by accident, negligence or misapplication or has been altered or modified in any way, including opening of the unit's casing for any reason. This warranty applies only to the original purchaser who must have properly registered the product within 10 days of purchase.

EXCEPT AS PROVIDED HEREIN, TRIPP LITE MAKES NO WARRANTIES, EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. Some states do not permit limitation or exclusion of implied warranties; therefore, the aforesaid limitation(s) or exclusion(s) may not apply to the purchaser. EXCEPT AS PROVIDED ABOVE, IN NO EVENT WILL TRIPP LITE BE LIABLE FOR DIRECT, INDIRECT, SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES ARISING OUT OF THE USE OF THIS PRODUCT, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE. Specifically, Tripp Lite is not liable for any costs, such as lost profits or revenue, loss of equipment, loss of use of equipment, loss of software, loss of data, costs of substitutes, claims by third parties, or otherwise.

Tripp Lite has a policy of continuous improvement. Specifications are subject to change without notice.

### Warranty Registration

Visit [www.tripplite.com/warranty](http://www.tripplite.com/warranty) today to register the warranty for your new Tripp Lite product. You'll be automatically entered into a drawing for a chance to win a FREE Tripp Lite product!\*

\* No purchase necessary. Void where prohibited. Some restrictions apply. See website for details.



1111 W. 35th Street, Chicago, IL 60609 USA  
(773) 869-1234 • [www.tripplite.com](http://www.tripplite.com)